



Beardsley Water Company 3 has completed the initial lead service line inventory required by U.S. EPA's Lead and Copper Rule Revisions. The deadline for the initial inventories is October 16, 2024.

Through completing a historical records review and field investigations, Beardsley Water Company 3 has determined it has no lead or galvanized requiring replacement service lines in its distribution system. This includes any privately-owned or customer-owned service lines.

Beardsley Water Company 3 reviewed all applicable sources of information, including

- All construction and plumbing codes, permits, and existing records or other documentation which indicates the service line materials;
- All water system records, including distribution system maps and drawings, historical records on each service connection, meter installation records, historical capital improvement or master plans, and standard operating procedures;
- All inspections and records of the distribution system that indicate service line material, including inspections conducted during the course of normal operations (e.g., checking service line materials when reading water meters or performing maintenance activities); and
- All previous service line or meter replacements were conducted.

After reviewing records and build dates, all service lines were verified as non-lead.

Beardsley Water Company 3 will update service line material information obtained from normal operations, such as service line maintenance, installation, or water meter readings, after October 2024 and will update the initial inventory accordingly.