



Liberty
 14920 W Camelback Rd
 Litchfield Park, AZ 85340
 Libertyutilities.com

Development Name: _____

Parcel: _____ Lot: _____

Address: _____ Utility Name: _____

_____ A new customer has signed in for service at this location. A repair is needed before account can be transferred.

_____ The meter requested at this location was not installed because of a repair needed.

_____ Other: _____

Please check the Item(s) below.

1. Meter box needs to be raised to 2.5" above back of curb.	2. Meter box needs to be leveled at 2.5" above curb.
3. Meter box needs to be free of excessive dirt and debris.	4. Lid needs to be replaced
5. Meter box is non-accessible	6. Customer valve needs to be removed from inside of meter box (City of Goodyear water valve)
7. AMS is damaged needs to be replaced	8. AMS set nut not tightened all the way and is moving.
9. Meter box not clearly marked with Lot #	10. Customer's shut off valve should be within 18" of meter box on customer's side
11. Meter box needs to be set	12. Meter box needs replacement
13. Meter needs to be moved 2" away from the back of the meter box	14. Meter box needs to be moved back away from 1" angel stop
15. Meter box needs to have at least 3ft to 2ft clearance from any barrier	16. Other (specify):

Notes: _____

Inspector Name: _____ Date Inspected: _____

Please send a photo of the updated installation so we can make another service call to verify that the repair has been completed



Photo(s):